





| | |
|---------------------|-----------------------|
| PRODUCT NO. | FB4CNF048L00EEAA |
| MODEL NO. | FB4CNF048 |
| SERIAL NO. | 1919F24671 |
| VOLTS | 208/230 |
| MOTOR HP | 3/4 |
| MOTOR FLA | 6.0 |
| PHASE/HERTZ | 1/60 |
| TEST STATIC | 0.20 IN. W.C. |
| REFRIGERANT | 410A DES. 3N PSIG 450 |
| DATE OF MANUFACTURE | MAY 2019 |



FB4CNF048L00EEAA



1919F24671

Approved Electric Heater Accessories

| | | | |
|---------------|---------------|---------------|---------------|
| KFCEH**01N05* | KFCEH**01C05* | KFCEH**01N08* | KFCEH**01C08* |
| KFCEH**01N09* | KFCEH**01N10* | KFCEH**01C10* | KFCEH**01F15* |
| KFCEH**01C15* | KFCEH**01315* | KFCEH**01318* | KFCEH**01F20* |
| KFCEH**01C20* | KFCEH**01F24* | KFCEH**01F30* | |

** - NUMERIC

ELECTRICAL INFORMATION FOR THIS UNIT

FOR FIELD INSTALLED ELECTRIC HEATERS APPLY ELECTRICAL INFORMATION
PLATE SUPPLIED WITH HEATER IN THIS BLOCK.

SINGLE SUPPLY CIRCUIT

| | | | |
|--------------------------|----|---------------|-----|
| L1/L2 HEATER AMPS | 0 | MIN. AMPACITY | 7.5 |
| MAX. OVERCUR. PROTECTION | 15 | | |

DUAL SUPPLY CIRCUIT

| | | | |
|--------------------------|-----|---------------|-----|
| L1/L2 HEATER AMPS | N/A | MIN. AMPACITY | N/A |
| MAX. OVERCUR. PROTECTION | N/A | | |
| L3/L4 HEATER AMPS | N/A | MIN. AMPACITY | N/A |
| MAX. OVERCUR. PROTECTION | N/A | | |

SHORT CIRCUIT CURRENT: 5ka RMS,
SYMMETRICAL, 230 V

HEAT PACK INSTALLED N/A

UNIT HAS INTEGRAL LIMIT CONTROL. MAX. OUTLET TEMP. 100F
MOTOR ELECTRONICALLY PROTECTED.

SEE INSTALLATION INSTRUCTIONS FOR SPECIFIC INSTALLATION REQUIREMENTS AND
APPROVED ACCESSORY KIT INFORMATION.

MAX. VOLTAGE TO GROUND OF SUPPLY CIRCUIT NOT TO EXCEED 120 VOLTS IF HEATER
HAS CIRCUIT BREAKER CONTROL.

COIL FOR COOLING ONLY EXCEPT WHEN INSTALLED AS PART OF A LISTED HEAT PUMP.
USE ONLY ACCESSORY ELECTRIC HEATERS SHOWN IN "APPROVED ACCESSORIES"
SECTION AND FROM EQUIPMENT MANUFACTURER.

CLEARANCE TO COMBUSTIBLE MATERIALS TO BE 0" FOR CASING, PLENUM AND DUCT FOR
UNITS WITH 0 TO 18KW HEATERS.

FOR UNITS WITH HEATERS 20KW AND ABOVE, CLEARANCE TO COMBUSTIBLE MATERIAL IS
TO BE 0" TO CASING AND 1" FOR FIRST 36" OF PLENUM AND DUCT.

CAUTION METERING DEVICE FOR THIS COIL MUST
MATCH THAT SHOWN ON OUTDOOR UNIT
RATING PLATE. REPLACE IF NECESSARY.
THIS UNIT IS EQUIPPED WITH METERING DEVICE.

80 PISTON

CAC/BDP
7310 W. Morris Street
Indianapolis, IN 46231 U.S.A.
342557-4174

ENGINEERED IN USA
ASSEMBLED IN MEXICO







