



Thanks for your payment

\$0.00 due

Invoice Summary



Always Plumbing & Drains

Keith Brown
23615 Breckenridge Forest Drive
Spring, TX 77373

📞 (281) 543-5461

INVOICE	#2501
SERVICE DATE	Mar 19, 2026
PAYMENT TERMS	Upon receipt
DUE DATE	Mar 19, 2026

AMOUNT DUE	\$0.00
------------	---------------

CONTACT US

8019 Marshall Falls Dr
Spring, TX 77379

📞 (832) 476-8121

✉️ aaalwaysplumbingllc@gmail.com

Service completed by: Jose Beltran

INVOICE

Services	qty	unit price	amount
----------	-----	------------	--------

Inspect plumbing in attic for proper strapping and leaks. 1.0 \$597.00 \$597.00

Due to noise in wall while finishing up running hot water in master bath.

Arrived on site and met Mr Brown. He told me about the slight popping noise going on between the wall of his master bath and daughter's bedroom. He said it's only in the mornings mainly and when the hot water is run. So I did run the hot water on both sinks and let it run until the water coming out got hot hot. And then I turned both faucets off. I heard the noise Mr brown was talking about.

That particular noise is created due to first the hose is piped in Cpvc. Up above in the attic the piping isn't really insulated other then 6 feet from every outer wall which is code. Other than that all the Cpvc piping is uninsulated. So when it gets cold outside and over night the pipe cools down completely. In the mornings when they start to use the hot water in the master bedroom sinks that hot water running thru the half inch piping starts to expand and contract slightly which is causing the noise in between the walls. There's no leaks, piping is strapped good in wall and up in attic. What I did do for the customer is add a shock station in the attic to make sure that there's no trapped air in the line. After you've run the sinks for a good minute that noise goes away. And doesn't come back until the next day if the attic gets really cold at night. That noise is very very normal and happens in all homes that have Cpvc in the attic and it's not fully insulated throughout the whole attic. But normal.

Next I swapped out a leaking angle stop and redid the drain piping to get the flexible tubing under kitchen sink. Last I swapped out the bad kitchen faucet and installed a new one.

Turned water back on after all work was completed to let the glue dry up in the attic. Checked all repairs for leaks and functuality. Everything is good with no leaks and functioning good.

Job completed.

Subtotal	\$597.00
Total Tax	\$0.00
state tax (8.025%)	\$0.00
Job Total	\$597.00
Amount Due	\$0.00
Tip	\$89.55

Payment History

Mar	Thu	Credit	\$686.55
19	10:43am	Card	

Thank you for choosing AAAlways Plumbing. We appreciate your business!

See our Terms & Conditions (<https://pro.housecallpro.com/AlwaysPlumbingDrains/247762/terms>)

Always Plumbing & Drains | 41144

<http://aaalwaysplumbing.com>

Contact us

(832) 476-8121



aaalwaysplumbingllc@gmail.com

