




Foundation Elevation Drawing

*NOT TO SCALE

SUNBELT INSPECTIONS

Date: 7/12/2023 Address: 16958 Nicole Ln



*NOT TO SCALE - The above drawing is a rough sketch of the foundation. The elevation measurements were taken with a Zipline 2000. Construction tolerance for foundations is $\pm 0.15"$ for 20' of measurement away from center. This drawing also serves as a benchmark of current foundation elevations.