



Certificate of Compliance WPI-8

Location of Property to be Insured

Street: 1115 NEWPORT BOULEVARD

Block:

City: League City

Lot:

Tract or Addition:

County: GALVESTON

Inside City Limits

Design wind speed 143 mph

International Residential Code, 2018 Edition - Risk Category II

Date of Construction: 05-15-2025

Application ID: 2436102

Occupancy Type: Residential

Certificate Number: 2436102

Building Type: House

Roof Partial Re-Roof June 11, 2025 Appointed Qualified Inspector

Location of Re-Roof: Sloped (6 12) sections of the house, exclude the patio cover on rear/northwest elevation, Number of Squares: 40, Product Evaluation Report Number: 250585, Comments: ASTM D3161 Class F; CertainTeed Lankmark Shingles on CertainTeed RoofRunner Synthetic Underlayment (ASTM D226 Type II) with CertainTeed Ridge Vent

This Certificate of Compliance, Form WPI-8, is issued by the Texas Department of Insurance under Insurance Code § 2210.251 and § 2210.2515 and demonstrates that the ongoing improvement identified in the certificate complies with the applicable windstorm building code under 28 Texas Administrative Code §§ 5.4007 – 5.4011.