

**Certificate of Compliance
WPI-8**

Location of Property to be Insured

Street: 2703 SABA LANE

Block:

City: PORT NECHES

Lot:

Tract or Addition:

County: JEFFERSON

Inside City Limits

Design wind speed 140 mph

International Residential Code, 2018 Edition - Risk Category II

Date of Construction: 03-12-2025

Application ID: 2428369

Occupancy Type: Residential

Certificate Number: 2428369

Building Type: House - Bldg Id: Main Dwelling - # of units: 1 -
SqFt: 68' x 40'

Roof Entire Re-Roof April 2, 2025 Appointed Qualified Inspector

Bldg: Main Dwelling; SqFt: 68' x 40'; # of units: 1; Comments: Installed 34 squares of Tamko Composite shingles with Tamko starter shingles. ABC pro guard underlayment and galvanized drip edge.

This Certificate of Compliance, Form WPI-8, is issued by the Texas Department of Insurance under Insurance Code § 2210.251 and § 2210.2515 and demonstrates that the ongoing improvement identified in the certificate complies with the applicable windstorm building code under 28 Texas Administrative Code §§ 5.4007 – 5.4011.